



Specifications

Lightning Plus Collection

HEAVY DUTY OPEN FACE ATHLETIC LOCKER

PART 1: GENERAL

1.01 Work Included

- A. The lockers shall be powder-coated steel as by Lightning Lockers, Toledo, Ohio.
- B. Furnish all labor and materials for completion of work in this section as shown in the approved drawings and specified herein.

PART 2: PRODUCT

2.01 Material-All major steel parts shall be of mild cold rolled commercial quality steel.

2.02 Finish-All material shall be power washed and phosphate treated for maximum finish color adhesion. All components shall be finished with a hybrid epoxy/polyester powder, electrostatically applied to ensure uniform thickness and baked to cure.

2.03 Construction-All lockers shall be built on a unit principle.

2.04 Ventilation-Open front; sides shall be diamond perf.

2.05 Body-Tops, bottoms, sides and shelves shall be 16 gauge; backs shall be 18 gauge. Bottoms shall have two welded reinforcement channels. Bolt spacing shall not exceed 9" o.c.

2.06 Interior Equipment-Locker shall have two wall hooks and one coat rod.

2.07 Number Plates-Each locker shall have a polished aluminum number plate riveted to door face with black numerals ½" high.

2.08 Color-All parts shall be finished in same color.

2.09 Assembly-All locker components shall be assembled with rivets or shall be factory welded.

2.10 Foot Locker-Front footlocker panel shall include a single point latch with padlock strike plate and mini louvers. Footlocker top shall have a continuous hinge. Opening and closing shall be quieted by rubber bumpers mounted to the contact points. Seat shall be strengthened with two reinforcement channels welded to bottom of seat. Two side seat supports shall be fastened to side panels and inserted in a support tab on the front locker panel for added strength.



2.11 Security Box-14 gauge lockable door with a 16 gauge side panel. The door shall be attached to a welded frame with a continuous hinge. The hinge shall be mounted to door with aluminum rivets. The door shall have a recessed single point latch handle. Security box door frame members to be not less than 16 gauge formed to a channel shape. Vertical members shall have an additional flange to provide a continuous door strike.

PART 3: EXECUTION

2.11 Installation-Lockers shall be installed in accordance with installation instructions and shall be level and plumb with flush surfaces and rigid attachment to anchoring surfaces.

Illustrations and descriptions herein are applicable to production as of the date of this catalog. The manufacturer reserves the right to make changes and improvements in designs and dimensions at any time.

Lightning Lockers LLC